

# ow\_reset

WMPRO >= 1.0 WMMEGA FW >= 2.0

Reset the OneWire bus

## Description

ow\_reset ( )

This function sends a reset signal to the OneWire bus. This is a low level function for custom OneWire bus operations.

## Parameters

None

## Return Values

None

## Example

```
<?
  ow_reset();
?>
```

## See Also

[ow\\_first\(\)](#) - Initiate a OneWire bus scan and return the address of the first device found

[ow\\_next\(\)](#) - Return the address of the next OneWire device found (after an [ow\\_first\(\)](#))

[ow\\_read\\_temp\(\)](#) - Read a temperature from a device on the OneWire bus

[ow\\_read\(\)](#) - Read a byte from the OneWire bus

[ow\\_write\(\)](#) - Write a byte to the OneWire bus

From:

<https://www.wattmon.com/dokuwiki/> - **Wattmon Documentation Wiki**

Permanent link:

[https://www.wattmon.com/dokuwiki/uphp/functions/ow\\_reset](https://www.wattmon.com/dokuwiki/uphp/functions/ow_reset)

Last update: **2021/09/13 05:57**

